

**Specific building characteristics with reference to the treated floor area**

		Treated floor area m <sup>2</sup>		Criteria	Alternative criteria	Fullfilled? <sup>2</sup>
Space heating	Heating demand kWh/(m <sup>2</sup> a)	4927.0	≤	15	-	yes
	Heating load W/m <sup>2</sup>	7	≤	-	10	
Space cooling	Cooling & dehum. demand kWh/(m <sup>2</sup> a)	2	≤	15	15	yes
	Cooling load W/m <sup>2</sup>	4	≤	-	13	
	Frequency of overheating (> 25 °C) %	-	≤	-	-	
	Frequency of excessively high humidity (> 12 g/kg) %	0	≤	10	-	
Airtightness	Pressurization test result n <sub>50</sub> 1/h	0.1	≤	0.6	-	yes
Non-renewable Primary Energy (PE)	PE demand kWh/(m <sup>2</sup> a)	151	≤	-	-	-
	PER demand kWh/(m <sup>2</sup> a)	70	≤	81	96	yes
Primary Energy Renewable (PER)	Generation of renewable energy (in relation to projected building footprint area) kWh/(m <sup>2</sup> a)	0	≥	-	43	

<sup>2</sup> Empty field: Data missing; '-': No requirement